

## **ELECTRICAL REPAIR OPTONS**

Replace all submerged electrical devices.

Replace all submerged wire:

1. Junction Box 2' above waterline and join new wire to old wire.
2. Replace all wire with new wire back to service panel
  - a. New wire must have Arc Fault Breaker
3. Install Outlets 2' above waterline.

Do Romex wires need to be replaced?

Wire and cable manufacturers at NEMA and Underwriters Laboratories (UL), state that Type NM-B cable (which includes Southwire's Romex Brand) needs to be removed if the cable has been submerged in flood waters.

Although the manufacturers of Type NM Cable (Romex) state that water-exposed cables must be replaced, we will accept a notarized statement from a licensed electrical contractor attesting to the cable's safety.

Sample Electrical Safety Letter

ACME ELECTRICAL  
12345 Lala Street N, Dream Land FL 1234  
LICENSE NUMBER

January 28, 2025

To Whom it may concern,

This is a letter to affirm we have inspected the electrical system at the property located at \_\_\_\_\_ and have found it safe to energize with the existing wires and devices.

Thank you,

**Signed And Notarized**

Copper Wire

Owner and License Holder

Phone Number: (727) 5675309